



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/ort TSE veya/ort T S E

BELGE NUMARASI REFERENCE NUMBER OF LICENCE	026216-TSE-01/03
BELGENİN İLK VERİLİŞ TARİHİ DATE OF FIRST ISSUE OF LICENCE	04.02.2010
BELGENİN SON GEÇERLİLİK TARİHİ LICENCE VALID UNTIL	04.02.2024
BELGE SAHİBİ KURULUŞUN ADI NAME OF THE LICENCE HOLDER	YILDIRIM ELSAN ELEKTİRİK İNŞAAT TAAHHÜT MÜHENDİSLİK HİZMETLERİ SANAYİ TİCARET LİMİTED ŞİRKETİ
BELGE SAHİBİ KURULUŞUN ADRESİ ADDRESS OF THE LICENCE HOLDER	AYDIN ORGANİZE SANAYİ BÖLGESİ 2.CADDE NO:41 UMURLU MERKEZ AYDIN/TÜRKİYE
ÜRETİM YERİ ADI NAME OF THE MANUFACTURING PLACE	YILDIRIM ELSAN ELEKTİRİK İNŞAAT TAAHHÜT MÜHENDİSLİK HİZMETLERİ SANAYİ TİCARET LİMİTED ŞİRKETİ
ÜRETİM YERİ ADRESİ ADDRESS OF THE MANUFACTURING PLACE	AYDIN ORGANİZE SANAYİ BÖLGESİ 2.CADDE NO:41 UMURLU MERKEZ AYDIN / TÜRKİYE
İPTAL EDİLEN BELGE NUMARASI (Varsa) INDICATION OF SUPERSEDED LICENCE (if any)	026216-TSE-01/02
TESCİLLİ TİCARİ MARKASI REGISTERED TRADE MARK	yespan
İLGİLİ TÜRK STANDARDI RELATED TURKISH STANDARD	TS EN 61439-2 / 09.10.2013 -- TS EN 61439-1 / 09.10.2013
BELGE KAPSAMI SCOPE OF LICENCE	



TYPE: 4000 A WITH INCOMING CIRCUIT BREAKER LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES

EXTERNAL DESIGN OF ASSEMBLIES: WITH ENCLOSURE
CONDITIONS OF INSTALLATION OF ASSEMBLIES: ASSEMBLY FOR INDOOR INSTALLATION
ACCESS TO MANUALLY OPERATED DEVICES: AUTHORIZED PERSONS
TYPE OF COOLING: FORCED COOLING

RATED VOLTAGE(Un): 400V
RATED OPERATIONAL VOLTAGE(Ue): 400 V
RATED IMPULSE WITHSTAND VOLTAGE(Uimp): 8 kV
IMPULSE WITHSTAND VOLTAGES OF AUXILIARY CIRCUITS(Uimp): -

e-imzalı/e-signed

26.05.2023

On Behalf Of The Head Of Certification Center
Ahmet NAMLI

Izmir Certification Manager



*This certificate also shows that the production place of the certified product meets the requirements of Institute.
*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.
*TSE Address: 8780/1 sokak No:5 Çiğli / İZMİR * Telephone: 0232 376 24 25(3H) * Fax: 0 232 445 42 32
*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail : bmb@tse.org.tr , web : www.tse.org.tr



Please check the accuracy and validity of the certificate from <https://evrakkontrol.tse.org.tr/BelgeDogrulama.aspx?p=9raayp3m>

1 / 5